

FMI

664

Farabee Mechanical Inc.

**P.O. Box 1748
Hickman, NE 68372-1748
Phone (402) 792-2612
Fax (402) 792-2712**

REC'D
MAY 10 2012
APCO

08 May 2012

Nebraska DEQ Air Toxics Division
1200 N St., Ste. 400
Lincoln, NE 68508

For: Red Cloud Municipal Power Plant, Red Cloud, NE

Please find enclosed the Initial Notice of Applicability. At this time, all generating units are being classified as non-emergency; however, this classification may change with the proposed definitions due later this month and to be finalized by year-end.

Respectfully,

FMI

Donna Oehm

Donna Oehm, CSM

cc: EPA Region 7
Director, Air & Waste Management
RE: RICE NESHAP ZZZZ
901 N 5TH St.
Kansas City, KS 66101

FMI

PO Box 1748
Hickman NE 68372-1748
Phone: (402) 792-2612
Fax: (402) 792-2712

Initial Notification of Applicability

National Emission Standards for Hazardous Air Pollutants:
Stationary Reciprocating Internal Combustion Engines
40 CFR part 63, subpart ZZZZ

☒ Yes, I am subject to 40 CFR Part 63 Subpart ZZZZ National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS Code(s): 221122 "Electric Power Distribution"

Compliance Date: ☒ Existing Source: May 3, 2013
☐ New/reconstructed source: upon initial startup

Company Name:	Red Cloud Municipal Power Plant
Facility Name (if different):	
Facility Physical Location Address:	1143 N. Webster Red Cloud, NE 68970

My facility is a: ☒ Area Source ☐ Major Source

Owner name / title:	City of Red Cloud
Owner/Company address:	540N. Webster
Owner telephone number:	(402) 746-2215
Owner email address (if available):	cityalbert@gpcom.net
Person to Contact:	
Name / Title:	Albert Wood, Superintendent
Telephone Number:	(402) 746-2214
Email address (if available):	cityalbert@gpcom.net

FMI

PO Box 1748

Hickman NE 68372-1748

Phone: (402) 792-2612

Fax: (402) 792-2712

Initial Notification of Applicability

National Emission Standards for Hazardous Air Pollutants:

Stationary Reciprocating Internal Combustion Engines

40 CFR part 63, subpart ZZZZ

Brief description of the stationary RICE at the facility, including number of engines and the site-rated HP of each engine:

Unit 2	Fairbanks-Morse 38DD8-1/8	1360 hp	non-emergency
Unit 3	Fairbanks-Morse 38DD8-1/8	1920 hp	non-emergency
Unit 4	Fairbanks-Morse 38DD8-1/8	1920 hp	non-emergency
Unit 5	Fairbanks-Morse 38TDD8-1/8	3175 hp	non-emergency

I hereby certify that the information presented herein is correct to the best of my knowledge.



(Signature)

5-Apr-12

(Date)

Albert Wood, Superintendent

(Printed Name/Title)

(402) 746-2214

(Telephone Number)

****Return both pages (signed) to FMI via fax or email: farabeecsm@inebraska.com**